

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-0533:100 Page 1 of 1

**CATEGORY:** Control Unit (Non High-Rise)

**LISTEE:** Viking, 210 N. Industrial Park Rd., Hastings MI 49058  
Contact: \*Eldon Jackson (616) 945-9501

**DESIGN:** Model B1. Inherently power-limited, non-coded, manual, automatic and water-flow alarm service (pre-action/deluge). Refer to listee's data sheet for system operational requirements and electrical rating.

**OPTIONS:** Refer to listee's data sheet for other required/optional accessories. When required, accessories shall be listed by CSFM.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as a control unit for use with separately listed compatible initiating and indicating devices.

For use as a proprietary protected premises unit, the system shall be interconnected with Potter Model EFT-C electrically actuated transmitter (CSFM Listing No. 7330-0328:104).

For central station protected remises unit, the system shall be connected to either of the following transmitters: ADEMCO Model 678UL-F (CSFM Listing No. 7330-0078:130); or Firelite Model NOTI-FIRE 911/911A series with ADEMCO Model 685 (CSFM Listing No. 7165-0078:133) control unit, or separately listed compatible control unit. When Firelite Model NOTI-FIRE 911/911A series is utilized, the system is not suitable for sprinkler supervisory service.

**NOTE:** XLF: 7165-0028:161

\*Rev. 09-25-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 19, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager